

Certificate of Product Approval

Certificate Number: 312p

Issue: 01

Bradbury Security Limited

6 Atkinsons Way
Foxhills Industrial Estate
Scunthorpe
North Lincolnshire
DN15 8QJ

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Products

Liddle Series 2 Security Barset
fixed security modular barsets

Standards

LPS 1175: Issue 8
Requirements and testing procedures for the LPCB certification and listing of intruder resistant building components, strongpoints, security enclosures and free-standing barriers

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Chris Hunt
Verifier

27 May 2022
Date of Issue

27 May 2022
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 312p Bradbury Security Limited

Issue: 01

Fixed Security Modular Barsets

Product Name	Type	Minimum Structural Opening Height (m)	Maximum Structural Opening Height (m)	Minimum Structural Opening Width (m)	Maximum Structural Opening Width (m)	Security Rating	LPCB Ref. No.
Liddle Series 2 Security Barset	Reveal mounted security bar set	0.4	3.0	0.4	3.0	B3 (SR2)	312p/01
	Internally or externally face fixed security bar set	0.1	2.54	0.1	2.54		

Dimensions of Individual Barset Units

Type	Configuration	Minimum Height (m)	Maximum Height (m)	Minimum Width (m)	Maximum Width (m)
Reveal mounted security bar set	Single unit barsets	0.4	1.8	0.4	1.0
	Multiple unit barsets	0.4	1.0	0.4	1.0
Internally or externally face fixed security bar set	Single unit barsets	0.56	1.8	0.56	1.0
	Multiple unit barsets	0.4	1.0	0.4	1.0

Notes:

- The barsets are either formed from a single unit or multiple units, each of which is of the dimensions listed in the table entitled 'Dimensions of Individual Barset Units'. The certification of barsets formed from multiple units only covers those assembled from a maximum of three individual units bolted together in each direction.
- The barsets are approved when installed in accordance with the instructions detailed on documents L2-SD-26 (Issue A) and L2-SD-27 (Issue A). The barsets are approved when installed directly to brickwork, concrete or steel. The approval does not cover the barsets when mounted to alternative substrates or via intermediate substrates such as plasterboard.

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Chris Hunt
Verifier

27 May 2022
Date of Issue

27 May 2022
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre